



Certificate of Analysis

M.J. Reider Associates, Inc.

ENVIRONMENTAL TESTING LABORATORY
U.S. EPA/PA DEP #06-00003

Laboratory No.: 9029522
Report: 09/05/19
Lab Contact: Christina M Kistler

Attention: Ricky Gautier
Reported To: Philadelphia Hebrew Public
3300 Henry Ave
Philadelphia, PA 19129

Project Info: DW Fountains

Lab ID: 9029522-01 **Collected By:** Victor M Baez **Sampled:** 08/23/19 11:48 **Received:** 08/23/19 14:30
Sample Desc: Fountain #1: Mess Hall **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	08/29/19		MPB

Lab ID: 9029522-02 **Collected By:** Victor M Baez **Sampled:** 08/23/19 11:48 **Received:** 08/23/19 14:30
Sample Desc: Fountain #2: Main Hallway **Sample Type:** Grab

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst
Total Metals							
Lead	<0.001	mg/l	0.001	EPA 200.8 Rev 5.4	08/29/19		MPB

Preparation Methods

Specific Method	Preparation Method	Prepared Date	Prepared By
9029522-01			
EPA 200.8 Rev 5.4	EPA 200.8 Rev 5.4	08/27/2019	MPB
9029522-02			
EPA 200.8 Rev 5.4	EPA 200.8 Rev 5.4	08/27/2019	MPB



107 Angelica Street ○ Reading, PA 19611 ○ www.mjreider.com ○ (610) 374-5129 ○ fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.

NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by CT (PH-0210), MD (261), NY(12094)